



ENLARGED PLAN - MECHANICAL
SCALE: 3/8" = 1'-0"

CONDENSING UNITS TO BE MOUNTED ON THE WALL WITH A MINIMUM CLEARANCE OF 18" FROM THE WALL. REFER TO THE MECHANICAL SPECIFICATIONS FOR MINIMUM CLEARANCE REQUIREMENTS BETWEEN CONDENSING UNITS.

DRAWING TITLE :
ENLARGED PLAN - MECHANICAL

PROJECT TITLE :
**Victor Distributing Company
NEW DISTRIBUTION CENTER
FORT MEYERS, FLORIDA**

Advanced Systems Engineering, Inc.
Project Engineer: David S. Bess
Manager: JLB
CAD: JLB
Job No. 14027.01
CA-8468
15000 Alvarado Boulevard, Suite 200, Channahon, IL 61310 • Office: 717.240.8190 • Fax: 717.240.8415
Copyright © 2011 - All rights reserved. No part of this document may be reproduced without the permission of ASE.

| REVISIONS |
|-----------|
| 1 |
| 2 |
| 3 |
| 4 |
| 5 |
| 6 |

JOB NO.: 14027.07
DRAWN BY: JLB
ISSUE DATE: 09.16.14
SHEET NUMBER: M2

